

## ***Aquasmart Technologies Inc.***

**Water purification, water and energy conservation systems**

**3122 Beta Avenue, Burnaby, B.C. Canada V.G. 4K4 Fax: (604) 294-0710 Phone: (604) 294-4041**

**E-mail:emily@aquasmart.com www.aquasmart.com Toll free: 1-888-294-3636**

### **Item # 255**

#### **Humidifier filter**

#### **With Polyphosphate & GAC**

**For taste, Odor, Chlorine reduction with Scale Inhibitor.**

#### Operating Specifications

Capacity: 6/9 months/1250 Gallons

Flow rate: 5 GPM

Maximum Pressure: 125 PSI

Temperature: 35-100 F (2-38 C)

Percentage reduction minimum: 95%

Flow passes from polyphosphate to the GAC

#### **Note flow direction of the filter with an arrow.**

For quick connection fittings, push a scratch free tube into the fittings until it bottoms. Threaded fittings must be wrapped with plumber's tape before installation. Install plumber's tape and tighten firmly. Use two wrenches to firmly tighten tubing.

Flush new filter out the first time, for minimum of five minutes, and every time it is replaced every 6-9 months. If leaks occur, check tightness of the tubing and fittings.

Replace filter when rated capacity (1250 Gallons, 6/9 months) is reached or when flow becomes too slow. Install in compliance with state and local laws and regulations.

#### Special note:

The contaminants or other substances removed or reduced by this water filter treatment system may not be necessarily in you water.

Do not use with water that is microbiologically unsafe, or of unknown quality without adequate disinfection before or after the system.